

**DEPARTMENT OF FORESTRY AND FIRE PROTECTION**

15670 Monterey St
Morgan Hill Ca 95037
408)779-2121
Website: www.fire.ca.gov



Ekundayo Sowunmi, P.E., QSD/QSP
Ackland International, Inc.
333 Hegenberger Road, Suite 304
Oakland, CA 94621

Variance to CCR, Title 14 SRA Fire Safe Regulations Approval
Sanborn Rd Saratoga APN 517-37-001,003

Mar 6, 2019

Dear Mr Sowunmi,

The request for variance for is approved based on the following items.

1. All driveways over 16 % grade will have a roughened asphalt or concrete surface. No portion of the driveway may exceed 20% grade.
2. An additional 5000 gallons of fire suppression water will be added to the project for each residence.

A handwritten signature in blue ink, appearing to read "Jake Hess".

Jake Hess
Unit Chief
Santa Clara Unit
CAL Fire

Cc Alex Goff
SCU File