



Date: 2/25/2020

Job#: 23009

To: Mark J. Connolly  
Senior Planner  
County of Santa Clara  
70 West Hedding Street  
San Jose, CA 95110  
408.299.5786 mark.connolly@pln.sccgov.org

Re: Responses to incomplete letter dated 3/27/2020  
Project Address: 14800 Pacheco Pass Highway, Gilroy, CA APN 779-15-001  
Plan Review Number: PLN20-018

Responses below directly correlate to items in said 3/27/2020 comments.

### **Planning**

1. Noted

### **LDE**

1. The questionnaire has been included in this resubmittal.
2. It was found that FEMA does not require existing bridges to meet freeboard requirements.
3. Flood plain location has been added to the plans.

### **Fire Marshall's Office**

4. Section notes have been added to sheets 2-5. Each road section complies with the standard width as requested. Notes added for slope, load capacity, vertical clearance and turning radius. Turnouts have been added to the plans.
5. Section notes for the individual driveways have been added to show the requested information.
6. Hydrants have been added to each parcel and shown on the plans.
7. Water tanks have been added to each parcel.

### **County Geologist:**

8. Mr Baker has been contacted to review the existing information on file for this project to determine if he needs anything additional.