

RESPONSE TO ALL

PLANNING RESPONSE:

1. N/A PER MEETING WITH VALERIE NEGRETE.
2. ALL CHANGES NOTED ON PLANS AND PER MEETING WITH VALERIE.
3. SET BACK SHOULD BE SHOWN/LISTED SHEET A-1.
4. EASEMENT SHOWN/LISTED SHEET A-1.
5. N/A PER MEETING WITH VALERIE.
6. N/A CLARIFIED IN MEETING WITH VALERIE.
7. COLOR BOARD AND PHOTOS OF EXISTING HOME ATTACHED.
8. ALL DETAILS WILL MATCH THAT OF EXISTING HOUSE NOTED AT SOUTH ELEVATION SHEET A-4.

FIRE MARSHAL RESPONSE:

9. NO COMMENTS FROM FIRE.

ENVIRONMENTAL HEALTH RESPONSE:

- 10/11. SEPTIC TANK, LEACH FIELD AND POOL SHOWN ON SITE PLAN SHEET A-1.  
PER PHONE CALL WITH JEFF CAMP 12/3/21, SEPTIC SYSTEM IS OK "AS IS" FOR SCOPE OF WORK. PUMP OUT REPORT ATTACHED.

12. SUBMITTED REQUESTED FORMS TO JEFF CAMP ON 1/19/22.

LAND DEVELOPMENT ENGINEERING RESPONSE:

13. PER MEETING WITH ERIC GONZALES, 2/1/22, THE EXISTING HOME STRUCTURAL VALUE IS \$2,119,500.00. THE COST OF IMPROVEMENTS = \$160,000 = 8%. IMPROVEMENTS ARE NOT SUBSTANTIAL.

GEOLOGY RESPONSE:

14. PER MEETING WITH JIM BAKER 2/1/22, THE ADDITION IS LESS THAN 500 SF, GEOLOGIC REPORT NOT REQUIRED.