

OWTS Feasibility Letter

(Proposed parcel #1 as shown on submitted site plan)

Owner Name: Juan Contreras

Site address: 11520 Murphy Av., San Martin CA 95046

Site APN: 835-05-055

Project Proposal: Septic Feasibility

Soil profiles: Date: 12/31/19 # of profiles: 2 Depth: 15 feet, GW @ 15'

Note: Hydrogeologic report dated 1/31/2020 states shallowest groundwater @12'

Percolation test: Date: 1/15/2020 # of holes: 6 Depth: 5 feet rate: Test failed due to fast percolation rate.

Percolation test: Date: 1/28/2020 # of holes: 6 Depth: 4 feet, 15 mpi

Application rate: 0.72 gpd/sqft

Proposed OWTS type: Conventional Trench or Pressure Distribution System

OWTS Details: Tank: TBD Dispersal field size: TBD

Water source: Well

OWTS plan date: No septic design submitted

Notes: This letter serves to show septic feasibility only. No septic (OWTS) design has been submitted nor approved at this time.

For septic design, please submit 4 copies of site plan showing all proposed structures, wells, and OWTS design to DEH for review. Submit one copy of proposed floor plan.

The OWTS permit will be issued at same time as building permit. Permit fee will be invoiced at that time.

OWTS approval: N/A

Date: 6/4/2020

Name: Jeff Camp, REHS

Signature:

For office use only:

Entered into envision and uploaded to Edocs Date:

Name: