

County of Santa Clara

Department of Planning and Development

County Government Center, East Wing, 7th Floor

70 West Hedding Street

San Jose, CA 95110

Phone: (408) 299-5700

www.sccplandev.org



January 18, 2023

Yogesh Chitlangia
15581 Glen Una Drive,
Los Gatos, CA 95030-2908

FILE NUMBER: PLN22-137
SUBJECT: Building Site Approval and Design Review Tier III
SITE LOCATION: 15581 Glen Una Drive, Los Gatos, CA 95030-2908 (APN: 510-26-007)
DATE RECEIVED: December 19, 2022

Dear Yogesh Chitlangia,

Your application for a Building Site Approval and Design Review Tier III was received on the above date and is deemed **incomplete**. For the application processing to resume, you must resolve the following issues and submit the information listed below.

Resubmittals are made via the internet, to do so, follow the instructions at the following URL: <https://plandev.sccgov.org/how/apply-permit/planning-resubmittal-procedures>. Before resubmitting, please consult me as this process is dynamic and at the time you choose to resubmit the process may have changed and/or been enhanced. The resubmitted materials must include all requested information. Once the information is submitted, the Planning Office will distribute the plans, reports and/or information to the appropriate staff or agency for review.

If you have any questions about the information being requested, you should first call the person whose name is listed as the contact person for that item. He or she represents a specialty or office and can provide details about the requested information.

AS NOTED ABOVE, PRIOR TO RESUBMITTAL PLEASE E-MAIL ME TO DISCUSS THE PROCESS.

Please submit *all* electronic copies of the revised plans/resubmittal documents (PDF) with a written response letter addressing each incomplete comment.

CALFIRE

Contact Carlos Alcantar at carlos.alcantar@fire.ca.gov for information regarding the following items.

This project is located within the State Responsibility Area (SRA) and is recommended to follow all minimum wildfire protection standards of **California Code of Regulations Title 14 Natural Resources Division 1.5 Department of Forestry Chapter 7 - Fire Protection Subchapter 2 SRA Fire Safe Regulations Articles 1-5.**

1. **Access:** Sections of Glen Una Drive do not meet specifications in § 1273.01 in the Fire Safe Regulations. Those sections of Glen Una Drive will need to conform to § 1273.01 to Building site and provide a minimum of two ten (10) foot traffic lanes, not including shoulder and striping.
 - *Please provide a map of the Glen Una Drive and show the two ten (10) foot traffic lanes, not including shoulder and striping, to represent that all the sections of the Glen Una Drive meet the specification.*

Article 2 Emergency Access and Egress

§ 1273.00. Intent

Roads and driveways, whether public or private, unless exempted under 14 CCR § 1270.02(d), shall provide for safe access for emergency wildfire equipment and civilian evacuation concurrently, and shall provide unobstructed traffic circulation during a wildfire emergency consistent with 14 CCR §§ 1273.00 through 1273.09.

§ 1273.01. Width.

- a. All roads shall be constructed to provide a minimum of two ten (10) foot traffic lanes, not including shoulder and striping. These traffic lanes shall provide for two-way traffic flow to support emergency vehicle and civilian egress, unless other standards are provided in this article or additional requirements are mandated by local jurisdictions or local subdivision requirements. Vertical clearances shall conform to the requirements in California Vehicle Code section 35250.
- b. All one-way roads shall be constructed to provide a minimum of one twelve (12) foot traffic lane, not including shoulders. The local jurisdiction may approve one-way roads.
 - 1) All one-way roads shall, at both ends, connect to a road with two traffic lanes providing for travel in different directions, and shall provide access to an area currently zoned for no more than ten (10) residential units.
 - 2) In no case shall a one-way road exceed 2,640 feet in length. A turnout shall be placed and constructed at approximately the midpoint of each one-way road.
- c. All driveways shall be constructed to provide a minimum of one (1) ten (10) foot traffic lane, fourteen (14) feet unobstructed horizontal clearance, and unobstructed vertical clearance of thirteen feet, six inches (13' 6").
 - *Your submitted Pro-rata justification letter does not satisfy the CalFire requirement of the Code section 35250. To meet the requirements all roads shall be constructed to provide a minimum of two ten (10) foot traffic lanes, not including shoulder and striping.*

Prior to resubmittal, please feel free to contact me to schedule an appointment so we can meet and discuss my comments regarding the project.

January 18, 2023
File No. PLN22-137
Glen Una Drive

Please make sure the requested changes are made for the revised plan sets and documents that are needed for the resubmittal. **Resubmittals are only accepted by appointment with the assigned project planner.** If the requested information is not submitted within **180 days**, you will be required to pay a fee of 10% of the application fee at the time the information is submitted. All requested information must be submitted no later than **one (1) year** from the date of this letter. PARTIAL RESUBMITTALS WILL NOT BE PROCESSED. Fees required at the time of resubmittal will be those in effect at that time.

Please note that the Grading Approval Application has been charged a minimum fee and will be charged additional fees to continue processing when the initial payment is exhausted.

In submitting this land use application, the owner/applicant included an initial application fee. Application fees are categorized as "fixed fees" and "billable fees", based on the particular application types. "Fixed fee" applications do not require any additional fees to continue processing. However, when funds associated with a "billable fee" application have been spent, an additional deposit will be required to continue processing the application.

If you have questions regarding the application, please contact me at (408)299-5783 or parya.seif@pln.sccgov.org.

Sincerely,

Parya Seif

Parya Seif
Associate Planner

cc:
Samuel Gutierrez, Principal Planner