



Date: 4/3/2024

Job#: 221125

To: Reva Kakaria
Assistant Planner
County of Santa Clara
70 West Hedding Street
San Jose, CA 95110
408.299.5792 reva.kakaria@pln.sccgov.org

Re: Responses to incomplete letter dated 12/19/2023
Project Address: 0 Grove Road, Los Gatos – APN 558-06-029
Plan Review Number: PLN22-192

Planning:

1. The fees have been paid.

Geology:

2. The Geology report addendum is included in the resubmittal.

Fire Marshal Office:

3. After further review with the water company, the water main along the road will be only 2” in diameter and extended from the nearest wharf hydrant. Please see included letter from the water company with the sizes and locations. Since the water line is not adequately sized for a standard hydrant, the wharf hydrant and tank remain.
4. See response to comment 3.
5. See response to comment 3.

Please let me know if you have any questions or need any additional information.

David Faria, PE

MH engineering Co.
Office: (408) 779-7381 Ext. 246
davidf@mhengineering.com