



January 2, 2024

Page 1 of 1

BUN 877196, APP 582266, Verizon Site Number: 300189

County of Santa Clara,

In response to 1st plan check comments made on December 29, 2023:

1. **Note of T-2, C-1.3, C-5.6, and E-1.2 that the generator will house the generator only.**

A note stating 'Note: Generator enclosure will be provided by the generator manufacturer for weather protection (see sheet C-5.6). Enclosure will enclose the generator only per the manufacturer standards. No other equipment will be enclosed by the generator enclosure.' has been placed on sheets T-2, C-1.3, C-5.6, and E-1.2.

Sincerely,

Tower Engineering Professionals, (TEP OPCO)

Joseph Cress

Project Manager